

CONDITIONS OF APPROVAL:

Open Issues: 1 These issues are currently being filtered

Water/Sewer

[2018-05-02 Standard at Cool Springs Lots 2-32 - Preliminary Plat Resubmittal.pdf](#)

**21. General issues**

[bnutt@mvud.org](mailto:bnutt@mvud.org)

- - FYI- No metering shown for the Lots 3-30(townhomes). Developer must submit application and fee so that we can determine design.
  - Water line and FH between Lots 23/24 shows a 6" feeding a FH located to rear of units is not approved, installed nor designed.