

COF no: 5980

CONDITIONS OF APPROVAL:

Fire-Planning

[2015.11.09_PUD Development Plan Submittal.pdf](#)

1. Fire Protection

- The requested fire flow has not yet been provided.

The applicant shall provide the results from a two-hydrant flow test to determine available water supply for fire protection.