

Legislation Details (With Text)

File #: 16-0902 **Version:** 1 **Name:** Contract 2016-0316
Type: Contract/Agreement **Status:** Passed
File created: 10/14/2016 **In control:** Board of Mayor & Aldermen
On agenda: 11/22/2016 **Final action:** 11/22/2016
Title: Consideration of a Professional Services Agreement (COF Contract No. 2016-0316) with Hazen and Sawyer for the 54-inch Harpeth River Interceptor Sewer Assessment Project in the Not-to-Exceed Amount of \$24,750.00 (Deferred from 10-27-16 Capital Investment Committee; 11/08/16 WS)
Sponsors: Paul Holzen, Mark Hilty, Patricia McNeese
Indexes:
Code sections:
Attachments: 1. COF 2016-0316 54-in Harpeth River Interceptor PSA_with attachment_Law Approved

Date	Ver.	Action By	Action	Result
11/22/2016	1	Board of Mayor & Aldermen	approved	Pass
11/8/2016	1	Work Session	referred as a Consent Item	
10/27/2016	1	Capital Investment Committee	referred	

DATE: October 27, 2016

TO: Board of Mayor and Aldermen

FROM: Eric Stuckey, City Administrator
Paul Holzen, P.E., Director of Engineering
Mark Hilty, P.E., Director of Water Management
Patricia McNeese, P.E., Utilities Engineer II

SUBJECT:

Consideration of a Professional Services Agreement (COF Contract No. 2016-0316) with Hazen and Sawyer for the 54-inch Harpeth River Interceptor Sewer Assessment Project in the Not-to-Exceed Amount of \$24,750.00 (Deferred from 10-27-16 Capital Investment Committee; 11/08/16 WS)

Purpose

The purpose of this memorandum is to provide information to the Franklin Board of Mayor and Aldermen (BOMA) concerning the Professional Services Agreement (PSA) (COF Contract No. 2016-0316) with Hazen and Sawyer for the 54-inch Harpeth River Interceptor Sewer Assessment Project.

Background

The existing 54-inch interceptor sewer that runs predominantly along the Harpeth River was installed in 2001. The sewer line is a fiber reinforced pipe. During the last 3 years, the City has discovered several failures and deficiencies in parts of this line. The purpose of this project is for the engineering consultant to review

previously recorded videos of inside the sewer line, to prepare a technical memo and to recommend repairs to the line, including estimated costs.

Financial Impact

The cost, as negotiated with Hazen and Sawyer, for the engineering services is a total amount not to exceed \$24,750.00. This project is to be funded from Sewer Operating Funds.

Recommendation

Staff recommends approval of the PSA (COF Contract No. 2016-0316) with Hazen and Sawyer for an amount not to exceed \$24,750.00.