



## Legislation Details (With Text)

**File #:** 18-0024      **Version:** 1      **Name:** COF 2017-0009  
**Type:** Item Approved on Behalf of the Board      **Status:** Passed  
**File created:** 12/27/2017      **In control:** Board of Mayor & Aldermen  
**On agenda:** 1/9/2018      **Final action:** 1/9/2018  
**Title:** Acknowledgement of Contract with American Fire Protection Group, Inc., for City Hall Fire Alarm Synchronization Work in an amount not to exceed \$2,500. (COF Contract # 2017-0009)  
**Sponsors:** Brad Wilson  
**Indexes:**  
**Code sections:**  
**Attachments:** 1. COF Contract 2017-0009

Date	Ver.	Action By	Action	Result
1/9/2018	1	Board of Mayor & Aldermen	approved	Pass

**DATE:** December 27, 2017

**TO:** Board of Mayor and Aldermen

**FROM:** Eric Stuckey, City Administrator  
Kristine Tallent, Assistant City Administrator/CFO  
Brad Wilson, Facilities Project Manager

**SUBJECT:** Acknowledgement of Contract with American Fire Protection Group, Inc., for City Hall Fire Alarm Synchronization Work in an amount not to exceed \$2,500. (COF Contract # 2017-0009)

### Purpose

The purpose of this memorandum is to provide information to the Franklin Board of Mayor and Aldermen (BOMA) that approval was given on behalf of the board to install cabling for proper synchronization of the visual fire alarm system within City Hall. [\$ 2,500.00]

### Background

During a routine inspection of the fire alarm system within City Hall, it was determined that the strobe warning system was not synchronized and could cause a health problem to some. Light flashes or off-timed strobes have been known to cause severe headaches and or seizures in persons that could result in hospitalization. It was determined after discussions with Fire and Safety personnel that it was a needed repair due to the many citizens that venture into City Hall.

### Financial Impact

The project amounted to a total cost of \$2,500 and will be funded through the facilities budget

**Recommendation**

Staff recommends services have been rendered at this time due to it being considered a safety concern within City Hall.