

## Legislation Details (With Text)

**File #:** 18-1108      **Version:** 1      **Name:**

**Type:** Contract/Agreement      **Status:** Passed

**File created:** 10/15/2018      **In control:** Board of Mayor & Aldermen

**On agenda:** 11/13/2018      **Final action:** 11/13/2018

**Title:** Consideration Of A Request For Sewer Availability Denial For 4649 Delta Springs Lane Map And Parcel 107H---01300 (10/25/18 CIC Recommended Request for Denial 3-0)

**Sponsors:** Michelle Hatcher

**Indexes:**

**Code sections:**

**Attachments:** 1. 4649 Delta Springs Lane - Map, 2. Availability Request Email, 3. LOT Plot map Delta Springs - Copy[4]

Date	Ver.	Action By	Action	Result
11/13/2018	1	Board of Mayor & Aldermen	approved	Pass
10/25/2018	1	Capital Investment Committee	referred as a Consent Item	Pass

**DATE:** October 15, 2018

**TO:** Board of Mayor and Aldermen

**FROM:** Michelle Hatcher, Director Water Management

**SUBJECT:**

Consideration Of A Request For Sewer Availability Denial For 4649 Delta Springs Lane Map And Parcel 107H---01300 (10/25/18 CIC Recommended Request for Denial 3-0)

**Purpose**

The purpose of this memo is to provide information to the Franklin Board of Mayor and Aldermen (BOMA) concerning a request for denial of sewer availability for the above referenced property.

**Background**

Date of Request: 9/13/18

SFUE's Requested: 1

Domestic Water Meter Size(s): N/A (Milcrofton Utility District)

This property is located outside of the City limits and is not within an acceptable distance to the City's Sewer mains.

**Financial Impact**

None.

**Recommendation**

Staff recommends that this availability denial request be approved.