



Legislation Text

File #: 16-0584, **Version:** 1

DATE: August 9, 2016

TO: Board of Mayor and Aldermen

FROM: Eric Stuckey, City Administrator
Brad Wilson, Facilities Project Manager

SUBJECT:

Acknowledge Report Of Sole-Source Purchase From Controlled Air Systems, LLC, Of Franklin In The Total Amount Of \$75,000 For Vehicle Exhaust Extraction Equipment For Fire Station 8. (Included As Part Of Fire Station 8's Project Budget.)

Purpose

The purpose of this memorandum is to provide information to the Franklin Board of Mayor and Aldermen (BOMA) concerning the sole source purchase.

Background

All of the City's Fire Stations utilize a vehicle exhaust, call a Plymovent system. A plymovent is a piece of equipment that exhaust the fumes from the fire apparatus equipment while it is parked in the bay and as the vehicle exits it breaks away. This keeps the facility's equipment bay clear of exhaust and in particular carbon monoxide, which can pose health risks. This equipment provided by Controlled Air Systems of Franklin, who is the sole source supplier in the area and handles the maintenance of the units.

Financial Impact

The purchase of this equipment is included as part of Fire Station 8's project budget

Recommendation

Staff recommends acknowledgement of sole source purchase