



## Legislation Text

---

**File #:** 16-1093, **Version:** 1

---

**DATE:** December 15, 2016

**TO:** Board of Mayor and Aldermen

**FROM:** Eric Stuckey, City Administrator  
Paul Holzen, P.E., Director of Engineering  
Mark Hilty, P.E., Director of Water Management  
Patricia McNeese, P.E., Utilities Project Manager

**SUBJECT:**

Consideration of A **DRAFT** Professional Services Agreement (COF Contract No. 2016-0330) with Hethcoat & Davis Inc. for the Holiday Court Sewer Pump Station Replacement in the Not-to-Exceed Amount of \$71,760.00

**Purpose**

The purpose of this memo is to provide information to the Franklin Board of Mayor and Aldermen (BOMA) concerning the Professional Services Agreement (COF Contract No. 2016-0330) for the Holiday Court Sewer Pump Station Replacement Project.

**Background**

The existing pump station was installed in the 1960s and is in desperate need of an upgrade. This upgrade will include a new wet well, valve vault, flow meter and emergency pump connection. No building will be included as it is assumed that the station will remain as currently configured as a small, stand-alone pump station with external mounted control panel and telemetry equipment. The existing 6" force main will be re-used rather than installing a new force main.

**Financial Impact**

The cost as negotiated with Hethcoat & Davis for the engineering services is a total amount not to exceed \$71,760.00. This project is to be funded from Sewer Operating Funds.

**Recommendation**

Staff recommends approval of the PSA with Hethcoat & Davis (COF Contract No. 2016-0330) for an amount not to exceed \$71,760.00.